

VOC Content Test Certificate

Tuesday 01st October 2019

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park, NSW 2164).

Sample Description: SikaFloor 158 W Fast Barrier

Date Tested: October 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B	SikaFloor 158 W Fast Barrier
One and two pack performance coatings for floors: 140 grams per Litre	4 grams per Litre as VOC content per material
<p><i>We hereby certify that SikaFloor 158 W Fast Barrier is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V1909074